




Storage, Storage Interfaces, Frequency Regulation, and Beyond

High MW Electronics – Industry Roadmap Meeting
Challenges to Growth of Grid Connected Electronics

National Institute of Standards & Technology


December 11th, 2009

Storage, Grid Applications




Source: ESA

Storage, System Characteristics Comparison




Source: ESA, * **modified** to include A123 in-service and proposed

Frequency Regulation with Storage (SGSS*)



SGSS provides power (discharges)
SGSS is charged by power plant/grid



* SGSS is A123's Smart Grid Stabilization System

Frequency Regulation, What's Delivered by PCS? Per CAISO Tariff, Controlled MW Output Level



A 1.2.1.2 the Generating Unit power output response (in MW) to a control signal must meet the minimum performance standards for control and unit response which will be developed and posted by the ISO on its internet "Home Page." As indicated by the Generating Unit power output (in MW), the Generating Unit must respond immediately, without manual Generating Unit operator intervention, to control signals and must sustain its specified ramp rate, within specified Regulation limits, for each minute of control response (MW/minute);

A 1.2.2 Monitoring:

the Generating Unit must have a standard ISO direct communication and direct control system to send signals to the ISO EMS to dynamically monitor, at a minimum the following:

A 1.2.2.2 high limit, low limit and rate limit values as selected by the Generating Unit operator; and

A 1.2.2.3 in-service status indication confirming availability of Regulation service.



** Point of Delivery Megavars is not required for AGC Regulation Units. However, it may be required in the future if a voltage market is established.

Delivering the Product, PCS Control and Tempo



 California ISO <small>Your Link to Power</small>	Technical Standard	Revision Date	2/20/2007
		Revision No.	4.6
		Print Date	2/26/2007
ISO Generation Monitoring and Control Requirements for AGC/Regulation Units		Effective Date	11/8/2004

Figure 1 - Timing of Telemetered Data for Generators Providing AGC through the RIG



#1 Driver – Storage F/R Commercially Viable



INDICATIVE COST OF PRODUCTION

42 mills CT Production Cost, 12 mills capacity, 30 mills variable cost

22 mills Battery Production Cost, 12 mills capacity, 10 mills variable cost

MARKET PRICE

10 – 50 mills Frequency Regulation average market clearing price

How can the PCS interface impact the “#1 Driver “ for deploying this solution?

Lower cost, increase efficiency, and improve reliability


... and also expand compensable capabilities.

But, barrier is not technology, it's lack of investment recovery mechanisms

See Slide 11

Industry research supports additional potential “drivers”, including emission reduction, renewable integration, system asset efficiency improvement . Once again, barrier is lack of investment recovery mechanism, not technology gaps.

One Implementation A123's Smart Grid Stabilization System (SGSS)



❖ Frequency Regulation

❖ Spinning Reserves

Grid Deployed SGSS's, Multi-MW Scale



California



Chile

Grid Interface, Parker-Hannifin



AC890PX Power Entry Types

TOP POWER ENTRY/EXIT



BOTTOM POWER ENTRY/EXIT



Four Operating Modes

- Volts/Hertz
- Sensorless vector
- Full flux vector
- Servo (PMAc)

Four Feedback Options

- Incremental encoder
- Sin/Cos encoder
- Endat absolute encoder
- Resolver



Runs induction, torque motors, or PMAc Servo

POWER INPUT AND OUTPUT


INVERTER PHASE MODULES

FILTER CAPS

CONVERTER


LINE REACTOR

FUSES



A Utility's Vision of Robust Storage Benefits

Locational Value of Energy Storage



PCS Capabilities For Full Grid Benefit

Steady State W, power transfer

Plus:

Steady State VAR, *voltage reg.*

Transient W, *a/c stall barrier*

Transient VAR, *sag mitigation*


Dynamic W, *damping, inertia*

Dynamic VAR, *voltage stability*

Islanding, *reliability*

Can this be delivered <\$3/watt?

First U.S. Retail Rate Case




values are based on studies made for an AEP site

Wind Challenge: Persistent Cycling Intermittency


PV Challenge: Infrequent Intermittency, Local PQ

Wind Production (Tehachapi)



PV Production (Tucson)


SGSSS 12/3/2006 1 Minute Power Changes for the Full System



Source: CAISO and TEP

BACKUP SLIDES

A123 Core Competencies



Materials
science and
development
expertise

Battery design
capabilities

Battery
systems
engineering
and
integration
expertise

Vertical
integration
from battery
chemistry to
battery
system design
services

Industry-
leading
partners in
focused
markets

High-quality,
volume
manufacturing
facilities and
proprietary
process
technologies

A123 Efficiencies for Maximum Value

